



We help ideas meet the real world



# Compliance Statement

No. 2010-092

## Data communication cable, Category 5e

### Company

Excel  
Excel House  
Junction Six Industrial Park  
Electric Avenue  
Birmingham, B6 7JJ  
United Kingdom

### Product description

Unshielded cable (U/UTP) characterised up to 100 MHz  
Horizontal floor wiring cable, 100  $\Omega$   
4 twisted pairs  
Flame retardant, PVC jacket

### Product identification

100-065

### Generic cabling standards, cabling components standard

- ISO/IEC 11801 2<sup>nd</sup> edition:2002 and IEC 61156-5: Edition 2.0 2009-02
- ISO/IEC 11801 amendment 2:2010
- EN 50173:2007
- ANSI/TIA-568-C.2

### Standard for flame retardancy

- IEC 60332-1-[1,2] (2004-07)

### Technical report

DELTA-N312740-01, DANAK-19J2222

### Manufacturer code

1771B

### Certificate valid until

7 May 2011

This product has been tested by EC Cabling Group of DELTA and complies with the requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 7 May 2010

Erik Bech  
Test Manager

Claude Videt  
Project Manager

DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
www.delta.dk/cable



DANAK  
TEST Reg. no. 19